



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Winter Crescent 3
3 Winter Crescent Reservoir
Contract No: 3657

Maintenance:

Date of Call: 24-12-2018
Time of Arrival: 11:31:00
Time of Departure: 13:31:00

Maintenance Details

Maintenance Description: Maintenance and Hazard & Risk Assessment

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safeties	Y
Clean & Check all M/R Equipment	Y
Clean out controller and check operation of various parts.	Y
Check tuning adjustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and adjust car & cwt guide shoes	Y
Check all safety switches, limits in lift well	Y
Check pit equipment and check water for pit	Y
Test Emergency Light Unit	Y
Pit Clean Report	Y
Test Lift Communications	Y

Service Technician

James Wallace

Customer Email