



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholas Building
37 Swanston St Melbourne
Contract No: 3265

Callouts:

Date of Call: 09-12-2018 13:24:00
Time of Arrival: 09-12-2018 13:50:00
Rectification Time: 09-12-2018 14:20:00
Time of Departure: 09-12-2018 14:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): g

Call Description: Lift 4 o.o.o

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): Remove Object From Doors

Work Description: Lift 4 o.o.o on ground error code 54 due to rubbish in door tracks. Removed rubbish reset ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

.