



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Melbourne
27 King St Melbourne
Contract No: P3304

Callouts: 22429

Date of Call: 29-11-2018 8:59:35
Time of Arrival: 29-11-2018 9:30:00
Rectification Time: 29-11-2018 10:40:00
Time of Departure: 29-11-2018 10:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 1

For Floor(s): ground

Call Description: lift doors are opening & closing, sensors are playing up, they have been cleaned and it is still happening

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Car door cam tension spring fault repaired spring, checked operation tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

george 0412288968