



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts:

Date of Call: 02-11-2018 1:50:00
Time of Arrival: 02-11-2018 2:35:00
Rectification Time: 02-11-2018 2:45:00
Time of Departure: 02-11-2018 3:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): g

Call Description: Ooo

Order Number: 15408

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): Clean Light Ray

Work Description: Checked, reset, cleaned and tested lift and lighr ray

Part Required: No Parts Required

Service Technician

Steven Johnson

Report Customer

0