



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Cooke Crt 2, Richmond (Building C)
2 Cooke Crt Richmond (Building C)
Contract No: P3548

Callouts:

Date of Call: 15-12-2018 9:00:00
Time of Arrival: 15-12-2018 9:24:00
Rectification Time: 15-12-2018 10:00:00
Time of Departure: 15-12-2018 10:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): B

Call Description: 3 Passengers Stuck

Order Number: TBC

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): Remove Object From Doors

Work Description: Lift reported SWP, lift ROA. Water ingress on level B causing debris to be pushed into door track, cleaner removed. Shut lift down due to large amount of water in pit requiring pumping.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

Jacobs