



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Plenty Ranges Arts & Convention Centre
35 Ferres Blvd Whittlesea
Contract No: S3042

Callouts ID: 22112

Date of Call: 26-10-2018 10:32:08
Time of Arrival: 26-10-2018 12:00:00
Rectification Time: 26-10-2018 12:33:00
Time of Departure: 26-10-2018 12:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Lakeview Room

For Floor(s): 1

Call Description: lift is out of order, stuck in between floors,

Order Number: 915892

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Obstructed light sensors by trolley in lift causing lift to stop.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#