



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Breakfree Heritage Hotel
318 Lt Bourke St Melbourne
Contract No: P3282

Maintenance ID:

Date of Call: 30-10-2018
Time of Arrival: 11:20:00
Time of Departure: 12:20:00

Maintenance Details

Maintenance Description: routine service\r\nemergency light failed,\r\nneed to upgrade emergency light unit to LED capable due to light fittings been changed from halogen to LED, notified building manager.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check car door operator and associated equipment.	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Robert Pelle

Customer Email

citycentral.maint@mantra.com.au