



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Werribee Mansion (Sofitel Hotel & Spa)
0 K Rd Werribee
Contract No: P3088

Callouts:

Date of Call: 15-11-2018 5:49:00
Time of Arrival: 15-11-2018 6:30:00
Rectification Time: 15-11-2018 7:00:00
Time of Departure: 15-11-2018 8:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2a

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Suspect level 2a doors hit out of alignment\r\nAdjust pick up roller assembly to increase cam clearance \r\nCheck door operation and test

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer