



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Prahran
27 King St Prahran
Contract No: P3433

Callouts: 22572

Date of Call: 12-12-2018 11:33:09
Time of Arrival: 12-12-2018 12:30:00
Rectification Time: 12-12-2018 15:15:00
Time of Departure: 12-12-2018 15:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Not Stopping Level

For Lift(s): 2

For Floor(s): G

Call Description: not leveling\r\n

Order Number: 16060

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Remove encoder and re make mounting bracket. Shim motor shaft and test - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

Sally