

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Bourke St 423, Melbourne
423 Bourke St Melbourne
Contract No: P3339

Callouts: 22422

Date of Call: 28-11-2018 10:51:10 Time of Arrival: 28-11-2018 14:55:00 Rectification Time: 28-11-2018 16:05:00 Time of Departure: 28-11-2018 16:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): ground

Call Description: out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Door error on ground floor,\r\ndoors timed out,\r\nreset car door operator,\r\nchecked car door operator equipment tested ok.

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle Ricky Chizik 0404 726 234