

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Pegasus Suites Hotel
206-216 A'Beckett St Melbourne
Contract No: P3382

## Callouts ID: 22022

Date of Call: 18-10-2018 9:07:00 Time of Arrival: 18-10-2018 9:30:00 Rectification Time: 18-10-2018 18:00:00 Time of Departure: 18-10-2018 18:00:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): ?

Call Description: lift 1 seems to be dropping from level to ground floor before a voice over

**Order Number:** x

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Overcurrent error logged on inverter.

Part Required: No Parts Required

Service Technician Report Customer

Gavin Pedlar