



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Brunswick St 150, Fitzroy**  
150 Brunswick St Fitzroy  
Contract No: P3511

## Callouts ID:

Date of Call: 28-10-2018 8:26:00  
Time of Arrival: 28-10-2018 8:50:00  
Rectification Time: 28-10-2018 9:05:00  
Time of Departure: 29-10-2018 9:28:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1,2

**For Floor(s):** 3

**Call Description:** Voth lifts not working

**Order Number:** 0

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** Reset Control System

**Work Description:** Fire brigade on site, no access to floors from the stair well. Check and closed the doors on level 3, reset the lift, adjusted and turned off the fire service recall switch.

**Part Required:** No Parts Required

**Service Technician**

Steven Johnson

**Report Customer**

0