



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Clayton Hotel
319 Clayton Road Clayton
Contract No: B3738

Callouts:

Date of Call: 06-12-2018 22:20:00
Time of Arrival: 06-12-2018 22:50:00
Rectification Time: 07-12-2018 0:15:00
Time of Departure: 07-12-2018 0:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 1

Call Description: Previously swp now out but lift ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift ooo drive fault led on\r\nError 65 motor contactors\r\nTest contactors all ok\r\nError 22 flashing on main board unable ti find info on error 22\r\nLed status ok but wont allow lift to run\r\nShut down overnight

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer