



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Bank Place 4, Melbourne
4 Bank Place Melbourne
Contract No: P3239

Maintenance:

Date of Call: 22-11-2018
Time of Arrival: 13:30:00
Time of Departure: 16:10:00

Maintenance Details

Maintenance Description: Routine service and supply and fitted new batteries for emergency light unit tested ok.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Clean out controller and check operation of various parts.	Y
Lubricate All Sheaves	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and adjust car & cwt guide shoes	Y
Check pit equipment and check water for pit	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Robert Pelle

Customer Email

mllaurence@teskacarson.com.au