



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Collins St 15, Melbourne
15 Collins St Melbourne
Contract No: P3334

Callouts ID: 22015

Date of Call: 16-10-2018 16:35:21
Time of Arrival: 16-10-2018 17:05:00
Rectification Time: 16-10-2018 17:25:00
Time of Departure: 16-10-2018 17:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 1

For Floor(s): G

Call Description: stuck on ground floor with doors opened

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Damage to light rays\r\nDamage to car buttons

Part Required: Light rays

Service Technician

Phil Dodsworth

Report Customer

David 0411 614 72