



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 341
341 Queen Street Melbourne
Contract No: P3719

Callouts: 22413

Date of Call: 27-11-2018 13:52:58
Time of Arrival: 28-11-2018 10:10:00
Rectification Time: 28-11-2018 11:10:00
Time of Departure: 28-11-2018 11:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1,3

For Floor(s): g

Call Description: lift 1 has no power, lift 3 the doors closed and not moving

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift 1 main switch tripped \r\nsuspected faulty SCR reset checked operation to be investigated further,\r\nlift 3 leveling fault checked contacts leveling circuit tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

luke 0396001184