



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Maribyrnong City Council - Municipal Offices (61 Napier St, Footscray)  
61 Napier St Footscray  
Contract No: 3395

**Callouts: 22250**

Date of Call: 09-11-2018 15:05:28  
Time of Arrival: 09-11-2018 15:25:00  
Rectification Time: 09-11-2018 15:45:00  
Time of Departure: 09-11-2018 15:45:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** S.W.P

**For Lift(s):** 1

**For Floor(s):** 2

**Call Description:** person stuck in lift

**Order Number:**

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Release passenger \r\nLift out of level \r\nLift shut down due to suspect faulty tape reader sensor

**Part Required:** No Parts Required

**Service Technician**

Matt Grieger

**Report Customer**

Mike 0411 457 611