



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Centre for Adult Education / Flinders Lane City Library
253 Flinders Lane Melbourne
Contract No: P3388

Callouts:

Date of Call: 13-11-2018 7:18:00
Time of Arrival: 13-11-2018 7:40:00
Rectification Time: 13-11-2018 7:50:00
Time of Departure: 13-11-2018 9:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): b

Call Description: SWP

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Reset Control System

Work Description: Overrun bottom reset and released passenger tested lift and returned lift to normal service

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

x