



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Derby St 56, Kensington
56 Derby St Kensington
Contract No: P3419

Callouts:

Date of Call: 03-11-2018 20:44:00
Time of Arrival: 03-11-2018 21:15:00
Rectification Time: 03-11-2018 21:40:00
Time of Departure: 03-11-2018 21:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): 4

Call Description: outer doors not opening on level 4

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Landing doors on level 4 not opening\r\nadjusted lock roller lift on ECI door locks\r\nchecked operation ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

simon