



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glenhuntly Rd 242, Elsternwick
242 Glenhuntly Rd Elsternwick
Contract No: P3449

Callouts:

Date of Call: 04-11-2018 17:20:00
Time of Arrival: 04-11-2018 17:50:00
Rectification Time: 04-11-2018 18:30:00
Time of Departure: 04-11-2018 18:42:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): 1

Call Description: passengers trapped inside lift.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: 2 passengers stuck in lift 150mm below level 1, \r\n car doors pulled open out of mesh \r\n suspected car door error, \r\n released passengers checked car door operation and landing doors on level 1 \r\n run and tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

peter