

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address: Inkerman St 150, St Kilda 150 Inkerman St St Kilda Contract No: P3460

Callouts: 22333

Date of Call: 19-11-2018 12:50:45 Time of Arrival: 19-11-2018 13:35:00 Rectification Time: 19-11-2018 13:43:00 Time of Departure: 19-11-2018 13:46:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: panel inside lift has been pulled out

Order Number: 15687

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 1 cop in car had been pulled out \r\nRe locked cop door in place

Part Required: No Parts Required

Service Technician Report Customer

Dwain Sanderson