



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts: 22699

Date of Call: 24-12-2018 10:16:27
Time of Arrival: 24-12-2018 10:24:00
Rectification Time: 24-12-2018 11:39:00
Time of Departure: 24-12-2018 23:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): car

Call Description: open door button has been pushed in.

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Door open button pushed in

Part Required: Door open button

Service Technician

Phil Dodsworth

Report Customer

Rebecca 96294171