



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Doncaster Rd 651, Doncaster
651 Doncaster Rd Doncaster
Contract No: P3483

Callouts: 22661

Date of Call: 19-12-2018 11:04:03
Time of Arrival: 19-12-2018 11:01:00
Rectification Time: 19-12-2018 12:01:00
Time of Departure: 19-12-2018 12:02:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): #

Call Description: person stuck in lift\r\n

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift with door fault. Fohnd doors wedged open out of floor caused by misuse of the lift. Lift had no fault after rectification.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

Daniel 0412346622