

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address: Wesley College (557 St Kilda Rd, St Kilda) 557 St Kilda Rd St Kilda Contract No: P3287

Callouts: 22496

Date of Call: 06-12-2018 13:13:08 Time of Arrival: 06-12-2018 14:00:00 Rectification Time: 06-12-2018 14:20:00 Time of Departure: 06-12-2018 14:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Closed

For Lift(s): 3

For Floor(s): .

Call Description: doors slamming shut in the music room lift

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Doors out of adjustment. Adjust doors ran and tested attended by kevin

Part Required: No Parts Required

Service Technician Report Customer

Brad Stellini