

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Aldi Dromana
120 Nepean Highway Dromana
Contract No: P3751

Callouts: 22516

Date of Call: 07-12-2018 16:26:36 Time of Arrival: 08-12-2018 12:00:00 Rectification Time: 08-12-2018 12:15:00 Time of Departure: 08-12-2018 12:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 1

Call Description: doors opening and closing on the first floor

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: Found door tracks full of dirt, grass, fluff etc and light ray very dusty. Clean tracks and clean light ray

Part Required: No Parts Required

Service Technician Report Customer

Kevin Wilkins REbecca 5987 2904