



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Clayton Hotel
319 Clayton Road Clayton
Contract No: B3738

Callouts: 22746

Date of Call: 02-01-2019 9:03:37
Time of Arrival: 02-01-2019 9:45:00
Rectification Time: 02-01-2019 10:10:00
Time of Departure: 02-01-2019 10:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: lift is out of order on ground floor

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Out of order paper being stuck on landing doors was caught between landing door panels preventing locks from making on ground

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

Elizabeth 0395628481