



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Wellington Street 240, Collingwood
240 Wellington Street Collingwood
Contract No: 3700

Callouts:

Date of Call: 15-12-2018 11:38:00
Time of Arrival: 15-12-2018 12:05:00
Rectification Time: 15-12-2018 12:20:00
Time of Departure: 15-12-2018 12:36:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 2

For Floor(s): G

Call Description: Lift not going down

Order Number: 16118

DESCRIPTION OF WORK

Fault Found (CAUSE): Loose Wire

Work Action (CORRECTION): Tighten Terminal

Work Description: Wire on level G button loose. Re-terminate and test. Ok.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

Jacobs