



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Prahran
27 King St Prahran
Contract No: P3433

Callouts:

Date of Call: 08-12-2018 12:34:00
Time of Arrival: 08-12-2018 15:20:00
Rectification Time: 08-12-2018 15:40:00
Time of Departure: 08-12-2018 16:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): g

Call Description: Displaying maintenance mode Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift displaying maintenance mode when on normal \r\nLift unable to move \r\nTraced circuit to pcb lcb all ok \r\nReset to clear fault and test

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer