



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts:

Date of Call: 29-12-2018 12:51:00
Time of Arrival: 29-12-2018 13:30:00
Rectification Time: 29-12-2018 13:45:00
Time of Departure: 29-12-2018 14:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): G

Call Description: Lift stopped ground floor with doors open.

Order Number: 16371

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Adjust ground floor locks.

Part Required: No Parts Required

Service Technician

Daniel Barry

Report Customer

.