



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts:

Date of Call: 31-12-2018 22:07:00
Time of Arrival: 31-12-2018 23:00:00
Rectification Time: 31-12-2018 23:12:00
Time of Departure: 31-12-2018 23:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): N/A

Call Description: Lift out of order with no passengers

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Reset Door Operator

Work Description: Door overload tripped. Reset door operator. Adjust level 3 landing doors. Run and tested, returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.