

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
The Alfred Main Ward Block
55 Alfred Main Ward Block Melbourne
Contract No: P3544

Callouts:

Date of Call: 23-12-2018 9:20:00 Time of Arrival: 23-12-2018 10:15:00 Rectification Time: 23-12-2018 10:50:00 Time of Departure: 23-12-2018 11:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2,3 For Floor(s): 4

Call Description: Lift 2 and 3 ooo

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 2 group coms error. Lift 3 contactor proving fault. Repair and test both lifts.

Part Required: No Parts Required

Service Technician Report Customer

mat tehan michael