



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Queen St 341
341 Queen Street Melbourne
Contract No: P3719

Maintenance ID:

Date of Call: 23-10-2018
Time of Arrival: 8:30:00
Time of Departure: 14:30:00

Maintenance Details

Maintenance Description: Replaced contactor leads on various contactors. Replaced exclusive key switch in lift no.3.

Maintenance Task	1	2	3
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y
Check all safety switches, limits in lift well	Y	Y	Y
check brake operation rope brake and associated equipment	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y
Check trailer flexes, attachments running clearance	Y	Y	Y
Test Lift Communications	Y	Y	Y

Service Technician

Gavin Pedlar

Customer Email

alex.singh@ankproperty.com.au;chakshu.daluja@ankcorp.com.au