



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

Logie St 13, Oakleigh  
13 Logie St Oakleigh  
Contract No: P3400

## Maintenance:

Date of Call: 03-12-2018  
Time of Arrival: 12:20:00  
Time of Departure: 13:30:00

### Maintenance Details

**Maintenance Description:** Regular service \r\nReplace lift fluro\r\nTennant (s) have been putting chewing gum in door tracks and in lift pit.\r\nGum had blocked basement door track. \r\nPlease advise this may cause faults/damage to lift.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safeties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check pit equipment and check water for pit	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

**Service Technician**

Zane Tregurtha

**Customer Email**

kparekh@vbcs.com.au