



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Cambridge St 120, Collingwood
120 Cambridge St Collingwood
Contract No: 3056

Callouts: 22423

Date of Call: 28-11-2018 12:08:39
Time of Arrival: 28-11-2018 12:16:00
Rectification Time: 28-11-2018 12:41:00
Time of Departure: 28-11-2018 12:53:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): G

Call Description: lift is not calling from ground floor to level 1 & 2

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift doors not hitting door vlose contact due to there being a peice of steel in the door track.\r\nPLZ advise customer: due to the life cycle of t lift being very out of date and motor components worn this lift is due for an upgrade asap.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#