



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Bayswater

0 Mountain Hwy & Station St Bayswater

Contract No: P3647

Callouts:

Date of Call: 14-12-2018 20:02:00
Time of Arrival: 14-12-2018 20:40:00
Rectification Time: 14-12-2018 22:00:00
Time of Departure: 14-12-2018 22:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): platform

Call Description: reported empty lift out of order

Order Number: 658315

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: error 54 on bottom landing doors checked car cam and lock rollers\r\nCleared fault tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

mark