



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Punt Hill - Chadstone Gateway (1384 Dandenong Rd, Oakleigh)
1384 Dandenong Rd Oakleigh
Contract No: P3292

Callouts:

Date of Call: 30-12-2018 13:51:00
Time of Arrival: 30-12-2018 14:05:00
Rectification Time: 30-12-2018 14:18:00
Time of Departure: 30-12-2018 14:23:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Chargeable Callout

For Lift(s): 1

For Floor(s): 2

Call Description: Lift out of order.

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: Vacuum cord hooked up on car door.\r\nLift doors unable to close.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x