

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 03 9687 9099 info@unitedlifts.com.au

Customer Details: Caulfield Park Pavilion 280 Balaclava Rd Caufield Contract No: P3399

Maintenance:

Date of Call: 21-11-2018 Time of Arrival: 14:30:00 Time of Departure: 15:09:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check and ajust car & cwt guide shoes	Y
Check pit equipment and check water for pit	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Lift Communications	Y

Service Technician

Customer Email

Dwain Sanderson

DHipsher@gleneira.vic.gov.au