



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Patterson Rd 60-66, Bentleigh
60-66 Patterson Rd Bentleigh
Contract No: P3247

Callouts:

Date of Call: 04-11-2018 15:14:00
Time of Arrival: 04-11-2018 15:45:00
Rectification Time: 04-11-2018 16:05:00
Time of Departure: 04-11-2018 16:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): ground

Call Description: lift not running

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Error 54,\r\nground floor landing door lock fault,\r\nsecond lock contact not making \r\nadjusted aircord on slow door \r\nchecked operation returned lift back to service.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Nicole