



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Cooke Crt 3, Richmond (Building D - East Block)
3 Cooke Crt Richmond (Building D - East Block)
Contract No: P3550

Callouts:

Date of Call: 02-11-2018 19:28:00
Time of Arrival: 01-11-2018 20:05:00
Rectification Time: 02-11-2018 8:05:00
Time of Departure: 02-11-2018 20:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s):

For Floor(s): 4-5

Call Description: Swp

Order Number: 15405

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Drive issues, main board not getting the drive ready input from the drive.

Part Required: No Parts Required

Service Technician

Steven Johnson

Report Customer

0