



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Crossley Hotel
51 Lt Bourke St Melbourne
Contract No: P3532

Callouts ID: 22067

Date of Call: 22-10-2018 16:30:19
Time of Arrival: 22-10-2018 16:47:00
Rectification Time: 22-10-2018 16:52:00
Time of Departure: 22-10-2018 16:52:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 3

For Floor(s): 6

Call Description: doors keep opening and closing on lv 6

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Cleaned dust off light ray .

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

Eve 9639 1639