



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

**Orrong Towers**  
723 Orrong Rd Toorak  
Contract No: P3186

## Maintenance:

Date of Call: 30-11-2018  
Time of Arrival: 13:50:00  
Time of Departure: 14:39:00

### Maintenance Details

**Maintenance Description:** Routine maintenance

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check pit equipment and check water for pit	Y
Test Lift Communications	Y

**Service Technician**

Nathan Downton

**Customer Email**