



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Caulfield Racecourse
22 Station Street Caulfield
Contract No: A3606

Callouts ID:

Date of Call: 19-10-2018 10:15:00
Time of Arrival: 19-10-2018 11:30:00
Rectification Time: 19-10-2018 12:40:00
Time of Departure: 19-10-2018 12:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): ESC 7

For Floor(s): 2

Call Description: Esc 7 stopping

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Door switches not fully closing. Stop esc and adjust. Run - ok.

Part Required: No parts required

Service Technician

Kevin Wilkins

Report Customer

.