



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Albert Redevelopment**  
140 Albert Road South Melbourne  
Contract No: W3688

## Callouts: 22396

Date of Call: 26-11-2018 12:09:40  
Time of Arrival: 26-11-2018 12:20:00  
Rectification Time: 26-11-2018 12:35:00  
Time of Departure: 26-11-2018 12:45:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** 16

**Call Description:** Out of order

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Door Lock Faulty

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Door lock fault on level 16 cleaned and adjusted door locks ran and tested

**Part Required:** No Parts Required

**Service Technician**

Brad Stellini

**Report Customer**

David 0414 324 894