

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Bowen Cres 3, Melbourne
3 Bowen Cres Melbourne
Contract No: P3031

Callouts: 22194

Date of Call: 05-11-2018 11:22:39 Time of Arrival: 05-11-2018 12:15:00 Rectification Time: 05-11-2018 12:45:00 Time of Departure: 05-11-2018 12:55:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): basement

Call Description: cant call the lift from the basement level

Order Number: .

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): Button Broken

Work Action (CORRECTION): Replace/Repair Button

Work Description: Lift running faulty button on basement

Part Required: Button

Service Technician Report Customer

Brad Stellini