



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Aurora (582 St Kilda Rd, Melbourne)  
582 St Kilda Rd Melbourne  
Contract No: P3402

## Callouts ID:

Date of Call: 30-10-2018 8:04:00  
Time of Arrival: 30-10-2018 8:20:00  
Rectification Time: 30-10-2018 9:00:00  
Time of Departure: 30-10-2018 9:10:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** S.W.P

**For Lift(s):** 1

**For Floor(s):** 9

**Call Description:** Lift 1 stuck on level 9 swp

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Faulty Contactor

**Work Action (CORRECTION):** Replace/Repair Reply or Contactor

**Work Description:** Lift had sb fault, sb1 contactor metered out high resistance, replaced sb1 and tested lift

**Part Required:** No Parts Required

**Service Technician**

Dwain Sanderson

**Report Customer**

concierge