



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glen Eira Town Hall

0 Corner Hawthorn Rd & Glen Eira Rd Caulfield

Contract No: P3399

Callouts ID: 21952

Date of Call: 09-10-2018 15:05:25

Time of Arrival: 09-10-2018 15:50:00

Rectification Time: 09-10-2018 16:37:00

Time of Departure: 12-10-2018 16:57:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): 2

Call Description: lift doors are stuck open on level 2

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift reported ooo with doors open on level 2
Cleaned doors and door tracks also cleaned DC do and dfc relay contacts tested lift

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

reception