



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Elgin Street 20, Carlton  
20 Elgin Street Carlton  
Contract No: P3117

## Callouts:

Date of Call: 08-12-2018 13:08:00  
Time of Arrival: 08-12-2018 13:45:00  
Rectification Time: 08-12-2018 14:55:00  
Time of Departure: 08-12-2018 14:55:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** See Fault Description

**For Lift(s):** 2

**For Floor(s):**

**Call Description:** No lights in lift

**Order Number:**

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Ups supply cb tripped in switch board \r\nUps supplies all lighting \r\nUnable to reset cb with all other cbs isolated indicating faulty ups\r\nN  
dhs to get ups company out

**Part Required:** No Parts Required

**Service Technician**

Matt Grieger

**Report Customer**