



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Brunswick St 150, Fitzroy**  
150 Brunswick St Fitzroy  
Contract No: P3511

## Callouts ID:

Date of Call: 25-10-2018 17:24:00  
Time of Arrival: 25-10-2018 18:00:00  
Rectification Time: 25-10-2018 18:20:00  
Time of Departure: 25-10-2018 18:35:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Chargeable Callout

**For Lift(s):** 1

**For Floor(s):** G

**Call Description:** Swipe card reader in lift not working

**Order Number:** 1

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift security swipe reader faulty. Not our side. Looks like it has been burt with a lighter.

**Part Required:** No Parts Required

**Service Technician**

Daniel Barry

**Report Customer**

.