



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts:

Date of Call: 27-11-2018 23:55:00
Time of Arrival: 28-11-2018 0:30:00
Rectification Time: 28-11-2018 1:00:00
Time of Departure: 28-11-2018 1:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 2

Call Description: Ooo doors open

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Error 37 and 6 logged on level 2 \r\nFault led on door operator\r\nFound door shoe broken on 12 landing doors\r\nPossibly jamming dood and
stopping from opening or closing properly\r\nReplaced shoe with new and test

Part Required: 1 door shoe

Service Technician

Matt Grieger

Report Customer