



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Bourke St 423, Melbourne
423 Bourke St Melbourne
Contract No: P3339

Callouts: 22349

Date of Call: 20-11-2018 12:57:56
Time of Arrival: 20-11-2018 13:15:00
Rectification Time: 20-11-2018 14:00:00
Time of Departure: 20-11-2018 14:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: lift is out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: safety circuit open in pit\r\nadjusted switch on counterweight buffer\r\nchecked operation ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

ricky 0404726234